

List of Warning Letters Issued to Registered Escalator Contractors (July 2023 - June 2024)

(1) 15 PM points non-compliant item(s) found, or conviction by the court/disciplinary board ^{Note1}

Month	Contractor No.	Name of Contractor	Brief Content of Warning Letter
9/2023	REC80001	Holake Hong Kong Lifts Ltd.	A total of 20 PM points were accorded for conviction by the court about the unsynchronized escalator handrail incident of Escalator No. 2 happened at Tropicana Garden, Lung Cheung Road, Wong Tai Sin, Kowloon on 4 October 2022.

(2) A total of 12 PM points or more involving maintenance non-compliant item(s) found in a single escalator inspection, or the average PM points exceeding 4 PM points within a 12-month period, or failure to comply with the provisions of the Lifts and Escalators Ordinance ^{Note2}

Month	Contractor No.	Name of Contractor	Brief Content of Warning Letter
-	-	-	-

The EMSD will issue a warning letter to the contractor under the following situations:-

Note 1: - 15 PM points non-compliant item(s) found in a single escalator inspection, or conviction by the court/ disciplinary board;

Note 2: - A total of 12 PM points or more involving maintenance non-compliant item(s) found in a single escalator inspection;

- The average PM points exceeding 4 PM points within a 12-month period; or
- Failure to comply with the provisions of the Lifts and Escalators Ordinance.