

Lift Equipment Failure Incident reported to EMSD (Jan 2024 to Jun 2024)

Contractor No.	Name of Contractor	Incident Date	Location	Incident Nature
RLC74002	Schindler Lifts (Hong Kong) Ltd.	11/02/2024	Discovery Park, 398 Castle Peak Road, Tsuen Wan, N.T.	Passenger tripping due to levelling difference of lift car at landing arisen from malfunction of electrical component
RLC75004	Otis Elevator Company (H.K.) Ltd.	30/05/2024	Tse On House, Yue On Court, 3 Yue On Court Road, Aberdeen	Passenger tripping due to levelling difference of lift car at landing arisen from malfunction of electrical component

No. of Equipment Failure Records = 2